



LEGEND

- AD = AIR LOAD INTERRUPTER SWITCH
- FCO = FUSED AIR CUT OUT
- OO = OIL LOAD INTERRUPTER SWITCH
- OFIS = OIL FUSED INTERRUPTER SWITCH
- OTS = OIL TRANSFER SWITCH
- SW = OIL, GAS, OR VACUUM SECTIONALIZING SWITCH
- VS = VACUUM INTERRUPTER SWITCH
- A1 FEEDER
- A2 FEEDER
- B1 FEEDER
- B2 FEEDER
- C1 FEEDER
- C2 FEEDER
- D1 FEEDER
- D2 FEEDER
- 21KV FEEDER
- SUB FEEDER
- MF1 FEEDER
- MF2 FEEDER
- BUILDING UNDER CONSTRUCTION
- EQUIPMENT AS NOTED
- EQUIPMENT AS NOTED WITH FAULTED CIRCUIT INDICATOR
- ELECTRICAL PULL BOX
- ELECTRICAL PULL BOX WITH EQUIPMENT AS NOTED
- ELECTRICAL PULL BOX WITH EQUIPMENT AS NOTED AND FAULTED CIRCUIT INDICATOR
- ELECTRICAL MANHOLE
- ELECTRICAL MANHOLE WITH EQUIPMENT AS NOTED
- ELECTRICAL MANHOLE WITH FAULTED CIRCUIT INDICATOR
- ELECTRICAL MANHOLE WITH EQUIPMENT AS NOTED AND FAULTED CIRCUIT INDICATOR

- FC-00 FUEL CELL REPLACEMENT BLOCK TAG
- GENERATOR SET INDICATOR TAG
- FC-01 KZSC TOWER HILL - 100KW + 100
- FC-02 ENGINEERING - 180 KW
- FC-03 COMMUNICATIONS/TRAVELER CO-GENERATION PLANT/NATURAL SCIENCES WOODSHOP - 425 KW
- FC-04 INTERDISCIPLINARY SCIENCE BLDG/EARTH & MARINE SCIENCES/SCIENCE LABS/NATURAL SCIENCES - 330 KW
- FC-05 PHYSICAL SCIENCES/ENGINEER LABS/BIOMED LABS/DEAR HALL - 600 KW
- FC-06 COLLEGE 9/10 - 715 KW
- FC-07 ORION COLLEGE/BERNELL COLLEGE/PIRE STATION - 185 KW
- FC-08 CORNELL HEALTH CENTER/STUDENT CENTER/CLASSROOMS/AMMUNITIES - 87.5 KW
- FC-09 CORNELL COLLEGE/STEVENS COLLEGE & APARTMENTS - 570 KW
- FC-10 MCKENRY LIBRARY/HARRIS STUDENT SERVICES - 31.5 KW + 199W STUDENT SERVICES
- FC-11 THE ARTS COMPLEX - 60 KW + DIGITAL ARTS
- FC-12 HRESSE COLLEGE/PORTER COLLEGE & PORTER/HRESSE APARTMENTS - 245 KW
- FC-13 HRESSE HOUSING EAST/UNIVERSITY STUDENT HOUSING/CORE WEST PARKING STRUCTURE - 285 KW
- FC-14 COLLEGE EIGHT AND OAKS COLLEGE - 488 KW
- FC-15 FAMILY STUDENT HOUSING - 180
- FC-16 EAST FIELD HOUSE/FITNESS CENTER/CP+ EVENTS CENTER COMPLEX - 180
- FC-17 QUARRY/VILLAGE/FARM/AGROECODOLOGY - 180
- FC-18 ARBORETUM - 180
- FC-19 BARN 6/BARN 1/CENTRAL STORES/SHAWNEE/CHANCE HOUSE/CHERRY HOUSE/FACULTY HOUSING - 30 KW + 180
- FC-20 EMERGENCY RESPONSE CENTER - 180

SEG
 ENGINEERING • PLANNING • DESIGN • CONSTRUCTION • E-DESIGN
 SURVEYING • PHOTOGRAMMETRY • VIDEO • PHOTOGRAPHY

3000 Highways Blvd. Suite 100
 Santa Cruz, CA 95061
 Phone: (408) 255-1700 Fax: (408) 255-1701
 www.seg.com

UNIVERSITY OF CALIFORNIA
 PHYSICAL PLANNING & CONSTRUCTION
 SANTA CRUZ CAMPUS
 SANTA CRUZ, CALIFORNIA

REVISIONS
 APPROVED
 D. LAWRENCE
 DRAWN
 B. MAGRE
 CHECKED

SHEET TITLE
 PROPOSED FUEL CELL
 REPLACEMENT BLOCK DISTRIBUTION MAP

BUILDING OR PROJECT
 ELECTRICAL MASTER PLAN
 2005-2020

FILE NO.
 9080
 SHEET
 2
 OF TWO